

ADDENDUM NO. 2

TO: ALL BIDDERS
PROJECT: ITB PW 32-20 – MISCELLANEOUS LANDSCAPE
IMPROVEMENTS
BID TIME AND DATE: 3:00 PM LOCAL TIME, June 17, 2020 (NO CHANGE)

June 08, 2020

The following items are hereby incorporated into the project manual, procurement documents, contract documents, plans and specifications:

ITEM NO. 1 – QUESTIONS RECEIVED POST ADVERTISEMENT

Question 1 – **“What is the total budget for this project?”**

Answer: Under \$400,000.00.

Question 2 – **“Please confirm the maintenance period for all three sites is one year.”**

Answer: Maintenance period is 1 (One) year. See Maintenance Notes on page 24 ((a)_SR 20 Hwy Beautification Release For Bid - Addendum No. 1 Drawings); and on sheet LD-30 (Set (b)_Emerald Coast Community Gateways_Release For Bid Drawings).

Question 3 – **“On Hwy 20, are we required to install 2 wells or, if we can meet design criteria, may we install only one well?”**

Answer: Respondent to base his bid on two wells.

Question 4 – **“Please explain or breakdown Bid Tab item #26 – Regular Excavation – 253 CY. What is this for and how will it be measured for payment?”**

Answer: Payment is Lump Sum for all excavation per planned quantities.

Question 5 – **“For the wells in Mary Esther and Destin, please confirm these are variable speed.”**

Answer: No variable speed pumps.

Question 6 – **“I assume for Hwy 20 we can install any well we want since there are no specifications. Please confirm.”**

Answer: Yes. If the design meets the specifications. See Irrigation Notes 1., 2., 3. sheet L-PL-4 ((a)_SR 20 Hwy Beautification Release For Bid - Addendum No. 1 Drawings).

END OF QUESTIONS

RECEIPT OF THIS ADDENDUM SHALL BE ACKNOWLEDGED BY WRITING THIS ADDENDUM NUMBER AND DATE IN THE SPACE PROVIDED ON DOCUMENT 00410-7, 'ADDENDUM ACKNOWLEDGEMENT - ATTACHMENT A.'

/s/ Roy Petrey _____

Roy Petrey, P.E.
Project Manager