

ADDENDUM NO. 2

TO: ALL BIDDERS
PROJECT: ITB PW 46-21 – VETERANS PARK
BID TIME AND DATE: 03:00 PM local time on June 09, 2021 No Change

June 1, 2021

The following items are hereby incorporated into the project manual, procurement documents, contract documents, plans and specifications:

ITEM NO. 1 – QUESTIONS RECEIVED SINCE PUBLICATION OF ADDENDUM NO. 1

Question 1: What type of Aggregate base is used under the sidewalks.?

Answer: Aggregate base is only required for paver construction, it is not proposed for sidewalks. Aggregate base for pavers shall be limerock, shell, or other approved material compacted to 95% modified proctor. All materials must conform to Okaloosa County Land Development code section 6.02.04 and this note:

NO FILL, BASE OR SOIL MATERIALS SHALL CONTAIN RED AND YELLOW CLAY, UNCLEAN SAND, OR SIMILAR MATERIALS CONTAINING DISCOLORING PARTICLES. FURTHER, ONLY WHITE OR OFF-WHITE MATERIALS WITH SIMILAR COLOR TO NATIVE SANDS SHALL BE ACCEPTABLE. ACCEPTABLE MATERIALS SHALL BE DETERMINED BY THE BUILDING OFFICIAL.

Question 2 - How high are the retaining walls?

Answer: The height of the gravity retaining walls vary. Please refer to the detail on C-027 showing embedment depth, and the existing, proposed, and top of wall elevations on sheets C-010 and C-011.

Question 3 - At the meeting I asked if we are to plan on Dewatering, the answer was no. Yet on the Bid sheet Dewatering is a line item. Should we plan on dewatering?

Answer: It is the contractor's responsibility to become familiar with the plans and the geotechnical report provided in the bid documents. The line item is provided if the contractor's means and methods require the need for dewatering.

ITEM NO. 2 – SECTION 00410 BID FORM WITH ATTACHMENTS

The \$30,000 Honor Wall Allowance is eliminated from the scope and bid form. Remove and replace BID TABULATION SHEET Page 00410-3 with revised Page 00410-3 included with this addendum.

BID TABULATION SHEET				
Veterans Park				
Okaloosa County, FL				
Pay Item	Unit	Unit Cost	Estimated Quantity	Cost
Mobilization	LS		1	
Maintenance of Traffic	LS		1	
Erosion Control	LS		1	
Dewatering	LS		1	
Demo/Clearing and Grubbing	LS		1	
Excavation	CY		2632	
Embankment	CY		718	
Plaza	LS		1	
Concrete Walkways	SF		12864	
Concrete Slabs	LS		1	
Detectable Warning	LS		1	
Striping	LS		1	
Signage	LS		1	
Parking Stops	EA		3	
Statue Installation	LS		1	
Statue Foundations	LS		1	
Honor Wall	LS		1	
This line intentionally left blank		N/A	1	N/A
Boardwalks	SF		3943	
Flagpoles	LS		1	
Retaining Walls	LS		1	
Park Benches	EA		5	
Trash Receptacles	EA		2	
Bicycle Racks	EA		2	
Pond Aeration	LS		1	
Landscaping	LS		1	
Restoration Plantings	LS		1	
Exotic & Nuisance Species Removal	LS		1	
Irrigation System	LS		1	
Electrical & Communication	LS		1	
As-Built	LS		1	
			TOTAL BID:	
Optional Services Pay Item				
Establishment Period Maintenance Plan. See Pay Item Note #24, Page C-004 of the Construction Drawings.	LS		1	

BID: For all work required to perform the work specified in the Bid Tabulation above in accordance with the construction drawings, specifications, and other contract documents, including all costs related to the work, and any required permits, taxes, bonds and insurance, the undersigned submits a total amount of:

RECEIPT OF THIS ADDENDUM SHALL BE ACKNOWLEDGED BY WRITING THIS
ADDENDUM NUMBER AND DATE IN THE SPACE PROVIDED ON DOCUMENT 00410-7,
'*ADDENDUM ACKNOWLEDGEMENT - ATTACHMENT A.*'

/s/ Roy Petrey
Roy Petrey, P.E.
Project Manager